## **SIEMENS**

## **Data sheet**

## 3SU1803-0AB10-4HB1



AS-Interface enclosure for command devices, 22 mm, round, Enclosure material plastic, enclosure top part gray, 3 control points plastic, Recess for labels, C=Indicator light clear, label without inscription, B=Pushbutton green, label: I, 1 NO, spring-type terminal, A=Pushbutton red, label: O, 1 NC, spring-type terminal, floor mounting, Insulation displacement system on top, Labels enclosed

product brand name	SIRIUS ACT
product designation	Enclosures
product type designation	3SU1
equipment of commanding and signaling device	A = Pushbutton / B = Pushbutton / C = Indicator light
manufacturer's article number	
<ul> <li>of supplied contact module</li> </ul>	A1 = 3SU1400-2AA10-3CA0 / B2 = 3SU1400-2AA10-3BA0
<ul> <li>of supplied contact module at the command point A</li> </ul>	3SU1400-2AA10-3CA0
<ul><li>of supplied contact module at the command point B</li></ul>	3SU1400-2AA10-3BA0
<ul> <li>of supplied LED module</li> </ul>	C3 = 3SU1401-2BB60-3AA0
<ul> <li>of supplied LED module at the command point C</li> </ul>	3SU1401-2BB60-3AA0
<ul> <li>of supplied communication module</li> </ul>	AB = 3SU1400-2EK10-6AA0
of the supplied holder	A = 3SU1500-0AA10-0AA0, B =3SU1500-0AA10-0AA0, C = 3SU1500-0AA10-0AA0
<ul> <li>of the supplied holder at the command point A</li> </ul>	3SU1500-0AA10-0AA0
<ul> <li>of the supplied holder at the command point B</li> </ul>	3SU1500-0AA10-0AA0
<ul> <li>of the supplied holder at the command point C</li> </ul>	3SU1500-0AA10-0AA0
<ul> <li>of the supplied actuator</li> </ul>	A = 3SU1000-0AB20-0AA0 / B = 3SU1000-0AB40-0AA0
<ul> <li>of the supplied actuator at the command point A</li> </ul>	3SU1000-0AB20-0AA0
<ul> <li>of the supplied actuator at the command point B</li> </ul>	3SU1000-0AB40-0AA0
<ul> <li>of the supplied actuator at the command point C</li> </ul>	3SU1001-6AA60-0AA0
<ul> <li>of supplied repeater</li> </ul>	C = 3SU1001-6AA60-0AA0
<ul> <li>of supplied empty enclosure</li> </ul>	3SU1803-0AA00-0AB1
of supplied accessory	A = 3SU1900-0AF16-0QA0, B = 3SU1900-0AF16-0QB0, C = 3SU1900- 0AF16-0AA0
<ul> <li>of the supplied accessories at the command point A</li> </ul>	3SU1900-0AF16-0QA0
<ul> <li>of the supplied accessories at the command point B</li> </ul>	3SU1900-0AF16-0QB0
<ul> <li>of the supplied accessories at the command point C</li> </ul>	3SU1900-0AF16-0AA0
Enclosure	
design of the housing	with recess for label
shape of the enclosure front	rectangular
material of the enclosure	plastic
number of command points	3
product component	
<ul> <li>EMERGENCY STOP device</li> </ul>	No
protective collar	No
color of the enclosure top part	grey
delivery state	
• as a kit	No

<ul> <li>pre-wired on strip terminal</li> </ul>	Yes
fastening method of the enclosure	Vertical
Actuator	
design of the actuating element	Pushbutton / pushbutton / indicator light
suitability for use EMERGENCY OFF switch	No
product feature lockout	No
product extension optional light source	Yes
color of the actuating element	A = red / B = green / C = clear
material of the actuating element	plastic
shape of the actuating element	round
number of contact modules	2
type of unlocking device	A = none / B = none / C = none
Front ring	
product component front ring	Yes
design of the front ring	Standard
material of the front ring	plastic
color of the front ring	black
Holder	
material of the holder	Plastic
Display	
number of LED modules	1
General technical data	
product function	
<ul> <li>positive opening</li> </ul>	Yes
<ul> <li>EMERGENCY OFF function</li> </ul>	No
EMERGENCY STOP function	No
protection class IP	IP66, IP67, IP69(IP69K)
degree of protection NEMA rating	1, 2, 3, 3R, 4, 4X, 12K, 13
shock resistance	
<ul><li>according to IEC 60068-2-27</li></ul>	sinusoidal half-wave 15g / 11 ms
for railway applications according to EN 61373	Category 1, Class B
vibration resistance	
according to IEC 60068-2-6	10 500 Hz: 5g
• for railway applications according to EN 61373	Category 1, Class B
reference code according to IEC 81346-2	S
continuous current of the C characteristic MCB	10 A; for a short-circuit current smaller than 400 A
continuous current of the quick DIAZED fuse link	10 A
continuous current of the DIAZED fuse link gG	10 A
Substance Prohibitance (Date)	10/01/2014
operating voltage	
at AC     — at 50 Hz rated value	24 24 V
— at 60 Hz rated value  — at 60 Hz rated value	24 24 V 24 24 V
at DC rated value      at DC rated value	24 24 V
cable entry type	Adapter ASI shaped cable (insulation displacement method) M20 cable
canto ona j tjeo	entry
Communication/ Protocol	
design of the interface for communication	AS-i
type of electrical connection of the communication	Insulation piercing technology top/right
interface	
Auxiliary circuit	
design of the contact of auxiliary contacts	Silver alloy
number of NC contacts for auxiliary contacts	1
number of NO contacts for auxiliary contacts	1
Connections/ Terminals	
type of electrical connection of modules and accessories	Spring-type terminal
type of electrical connection on enclosure	Adapter ASI shaped cable (insulation displacement method)
tightening torque of the screws in the bracket	1 1.2 N·m
tightening torque of fixing screws in the enclosure	1.5 1.7 N·m
cover	

Lawre		
Lamp		
light intensity	900 1 400 mcd	
Ambient conditions		
ambient temperature		
<ul> <li>during operation</li> </ul>	-25 +70 °C	
during storage	-40 +80 °C	
environmental category during operation according to IEC 60721	3M6, 3S2, 3B2, 3K6 (with relative air humidity of 10 95%, no condensation in operation permitted for all devices behind front panel)	
Installation/ mounting/ dimensions		
fastening method of modules and accessories	Floor mounting	
height	174.4 mm	
width	85 mm	
depth	75.8 mm	
shape of the installation opening	round	
Accessories		
number of labels	3	
marking of the name plate for command devices	A = O / B = I / C = without inscription	
color of the label	A = black / B = black / C = black	
number of inscription plates	0	
Certificates/ approvals		
General Product Approval		

**@** 

Confirmation









Declaration of Conformity Test Certificates other



Special Test Certificate Type Test Certificates/Test Report

Confirmation

Environmental Confirmations

## **Further information**

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SU1803-0AB10-4HB1

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3SU1803-0AB10-4HB1

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3SU1803-0AB10-4HB1

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ EPLAN\ macros,\ ...)$ 

http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3SU1803-0AB10-4HB1&lang=en

last modified: 1/26/2022 🖸