## SIEMENS

## Data sheet

## 3RS7000-2DE00



Separation amplifier 24 V AC/DC, 3-way separation input: 0-10 V output: 4-20 mA Spring-type terminal (push-in)

product brand name	SIRIUS
product category	Signal converter
product designation	Single-range converters
design of the product	active
product type designation	3RS70
General technical data	
display version LED	Yes
number of channels	1
consumed active power	0.29 W
insulation voltage for overvoltage category III according to IEC 60664 with degree of pollution 3 rated value	50 V
surge voltage resistance rated value	2 500 V
protection class IP	IP20
shock resistance according to IEC 60068-2-27	sinusoidal half-wave 15g / 11 ms
vibration resistance according to IEC 60068-2-6	6 150 Hz: 2 g
reference code according to IEC 81346-2	Т
Substance Prohibitance (Date)	03/25/2015
Supply voltage	
supply voltage at AC	
<ul> <li>at 50 Hz rated value</li> </ul>	24 V
• at 60 Hz rated value	24 V
supply voltage at DC rated value	24 V
supply voltage frequency rated value	60 50 Hz
operating range factor supply voltage rated value	
• at AC at 50 Hz	0.8 1.1
• at AC at 60 Hz	0.8 1.1
• at DC	0.8 1.1
Precision	
relative metering precision	0.1 %
relative linearity deviation	0.05 %
temperature drift per °C	0.015 %/°C
voltage ripple maximum	20 mV
limit frequency	30 Hz
settling time for 1 % deviation	17 ms
rise time	6 ms
Main circuit	
type of voltage	AC/DC
Inputs/ Outputs	
input voltage	30 V

property of the output chart sizewith proof	Vac
property of the output short-circuit proof	Yes 0 10 V
type of signal at input type of signal at output	4 20 mA
input impedance of voltage input minimum	4 20 mA 330 kΩ
output load	000 122
at the current output maximum	500 Ω
Electromagnetic compatibility	
EMC emitted interference according to IEC 60947-1	Environment B
EMC immunity according to IEC 60947-1	corresponds to degree of severity 3
conducted interference	concepting to degree of sevenity o
due to burst according to IEC 61000-4-4	1 kV 5/50 ns
due to conductor-conductor surge according to IEC	1 kV
61000-4-5	
field-based interference according to IEC 61000-4-3	10 V/m
electrostatic discharge according to IEC 61000-4-2	6 kV contact discharge / 8 kV air discharge
Galvanic isolation	
design of the electrical isolation	3 paths
galvanic isolation	
<ul> <li>between input and output</li> </ul>	Yes
<ul> <li>between the outputs</li> </ul>	No
between the inputs	No
<ul> <li>between the voltage supply and other circuits</li> </ul>	Yes
Connections/ Terminals	
type of electrical connection	spring-loaded terminals
type of connectable conductor cross-sections	
• solid	1x (0.25 2.5 mm <sup>2</sup> )
<ul> <li>finely stranded with core end processing</li> </ul>	1x (0.25 1.5 mm <sup>2</sup> )
finely stranded without core end processing	1x (0.25 2.5 mm <sup>2</sup> )
at AWG cables solid	1 x (20 14)
at AWG cables stranded	1x (20 14)
connectable conductor cross-section	0.25 2.5 mm²
<ul> <li>solid</li> <li>finally stranded with some and processing</li> </ul>	0.25 2.5 mm <sup>2</sup>
<ul> <li>finely stranded with core end processing</li> <li>finely stranded without core end processing</li> </ul>	$0.25 \dots 2.5 \text{ mm}^2$
AWG number as coded connectable conductor cross	
section	
• solid	20 14
• stranded	20 14
Installation/ mounting/ dimensions	
mounting position	any
fastening method	snap-on mounting
height	93 mm
width	6.2 mm
depth	72.5 mm
required spacing	
with side-by-side mounting	
— forwards	0 mm
— backwards	0 mm
— upwards	0 mm
— downwards	0 mm
— at the side	0 mm
<ul> <li>for grounded parts</li> <li>forwards</li> </ul>	0 mm
— torwards — backwards	0 mm 0 mm
— upwards	0 mm
— upwards — at the side	0 mm
— at the side — downwards	0 mm
• for live parts	
— forwards	0 mm
— backwards	0 mm

at the side       0 mm         Ambient conditions       2 000 m         installation altitude at height above sea level maximum       2 000 m         ambient temperature       -25 +60 °C         - during operation       -25 +60 °C         - during storage       -40 +80 °C         - elative humidity during operation       -40 +80 °C         relative humidity during operation       10 95 %         Certificates/ approvals       Declaration of Conformity         General Product Approval       Test Certificate Certi
Ambient conditions       2 000 m         installation altitude at height above sea level maximum       2 000 m         ambient temperature       -25 +60 °C         • during operation       -25 +60 °C         • during storage       -40 +80 °C         • during transport       -40 +80 °C         • during transport       -40 +80 °C         relative humidity during operation       10 95 %         Certificates/ approvals       Declaration of Conformity       Test Certificate rates/Test Reg         Image: Confirmation       Image: Confirmation       Image: Certificate rest rest       Image: Certificate rest rest
installation altitude at height above sea level maximum       2 000 m         ambient temperature       -25 +60 °C         • during operation       -25 +60 °C         • during storage       -40 +80 °C         • during transport       -40 +80 °C         relative humidity during operation       10 95 %         Declaration of Certificates/ approvals         General Product Approval         Declaration of Confirmation       Test Certificates/ ates/Test Reg
ambient temperature       -25 +60 °C         • during operation       -25 +60 °C         • during storage       -40 +80 °C         • during transport       -40 +80 °C         relative humidity during operation       10 95 %         Certificates/ approvals         General Product Approval         Confirmation       Image: Confirmation         Confirmation       Image: Confirmation         Confirmation       Image: Confirmation         Image: Confirmation       Image: Co
<ul> <li>during operation</li> <li>during storage</li> <li>during storage</li> <li>during transport</li> <li>during transport</li> <li>during transport</li> <li>during operation</li> <li>-40 +80 °C</li> <li>-40 +80 °C</li> <li>-40 +80 °C</li> <li>10 95 %</li> </ul> Certificates/ approvals           Certificates/ approvals         Declaration of Conformity         Test Certificates/ approvals
• during storage     -40 +80 °C       • during transport     -40 +80 °C       relative humidity during operation     10 95 %       Certificates/ approvals     Declaration of Conformity     Test Certificate rest Certificates       General Product Approval     Declaration of Conformity     Type Test Certificates       Confirmation     Confirmation     Effet     C €
• during transport     -40 +80 °C       relative humidity during operation     10 95 %       Certificates/ approvals     Declaration of Conformity     Test Certification       General Product Approval     Image: Confirmation of Conformity     Image: Certification of Conformity     Image: Certification of Conformity       Image: Confirmation of Confirmation     Image: Certification of Confirmation     Image: Certification of Confirmation     Image: Certification of Confirmation
relative humidity during operation     10 95 %       Certificates/ approvals     Declaration of Conformity     Test Certification       General Product Approval     Declaration of Conformity     Test Certification       Image: Confirmation     Image: Confirmation     Image: Certification of Confirmation     Image: Certification of Confirmation
Certificates/ approvals         General Product Approval       Declaration of Conformity       Test Certification         Image: Confirmation of Confirmation       Image: Confirmation of Confirmation       Image: Certification of Confirmation       Image: Certification of Confirmation         Image: Confirmation of Confirmation       Image: Certification of Confirmation       Image: Certification of Confirmation       Image: Certification of Confirmation         Image: Confirmation of Confirmation       Image: Certification of Confirmation       Image: Certification of Confirmation       Image: Certification of Confirmation         Image: Confirmation of Confirmation       Image: Certification of Confirmation       Image: Certification of Confirmation       Image: Certification of Confirmation         Image: Confirmation of Confirmation       Image: Certification of Confirmation       Image: Certification of Certification of Certification       Image: Certification of Certificatio of Certification of Certification of Certification o
General Product Approval     Declaration of Conformity     Test Certification       Image: Confirmation of Confirmation     Image: Confirmation of Confirmation     Image: Confirmation of Confirmation     Image: Confirmation of Confirmation
Marine / Shipping other
Further information
Information- and Downloadcenter (Catalogs, Brochures,) https://www.siemens.com/ic10
Industry Mall (Online ordering system)
https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RS7000-2DE00
Cax online generator http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RS7000-2DE00
Service&Support (Manuals, Certificates, Characteristics, FAQs,) https://support.industry.siemens.com/cs/ww/en/ps/3RS7000-2DE00

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3RS7000-2DE00&lang=en

Characteristic: Derating

https://support.industry.siemens.com/cs/ww/en/ps/3RS7000-2DE00/manual

last modified:

12/23/2020 🖸