## SIEMENS

## Data sheet

## 3RA2316-8XB30-1BW4

Reversing contactor assembly AC-3, 4 kW/400 V, 48 V DC 3-pole, Size S00 screw terminal electrical and mechanical interlock



product brand name	SIRIUS				
product designation	Reversing contactor assembly				
product type designation	3RA23				
manufacturer's article number					
<ul> <li>1 of the supplied contactor</li> </ul>	<u>3RT2016-1BW42</u>				
<ul> <li>2 of the supplied contactor</li> </ul>	<u>3RT2016-1BW42</u>				
<ul> <li>of the supplied RH assembly kit</li> </ul>	<u>3RA2913-2AA1</u>				
General technical data					
size of contactor	S00				
product extension auxiliary switch	Yes				
shock resistance at rectangular impulse					
• at AC	6,7g / 5 ms, 4,2g / 10 ms				
• at DC	6,7g / 5 ms, 4,2g / 10 ms				
shock resistance with sine pulse					
• at AC	10,5g / 5 ms, 6,6g / 10 ms				
• at DC	10,5g / 5 ms, 6,6g / 10 ms				
mechanical service life (switching cycles)					
<ul> <li>of contactor typical</li> </ul>	10 000 000				
<ul> <li>of the contactor with added auxiliary switch block typical</li> </ul>	10 000 000				
reference code according to IEC 81346-2	Q				
Substance Prohibitance (Date)	10/01/2009				
Ambient conditions					
installation altitude at height above sea level maximum	2 000 m				
ambient temperature					
<ul> <li>during operation</li> </ul>	-25 +60 °C				
<ul> <li>during storage</li> </ul>	-55 +80 °C				
Main circuit					
number of poles for main current circuit	3				
number of NO contacts for main contacts	3				
number of NC contacts for main contacts	0				
operating voltage at AC-3 rated value maximum	690 V				
operational current at AC-3					
• at 400 V rated value	9 A				
• at 500 V rated value	7.7 A				
• at 690 V rated value	6.7 A				
operating power					
• at AC-3					
— at 400 V rated value	4 kW				

— at 500 V rated value	4 kW			
— at 690 V rated value	5.5 kW			
at AC-4 at 400 V rated value	4 kW			
operating frequency at AC-3 maximum	750 1/h			
Control circuit/ Control				
type of voltage of the control supply voltage	DC			
control supply voltage 1				
at DC rated value	48 V			
closing power of magnet coil at DC	4 W			
holding power of magnet coil at DC	4 W			
Auxiliary circuit				
contact reliability of auxiliary contacts	< 1 error per 100 million operating cycles			
UL/CSA ratings	· · · · · · · · · · · · · · · · · · ·			
full-load current (FLA) for 3-phase AC motor				
• at 480 V rated value	7.6 A			
at 600 V rated value	9 A			
yielded mechanical performance [hp] for 3-phase AC motor				
at 200/208 V rated value	2 hp			
at 220/230 V rated value	3 hp			
• at 460/480 V rated value	5 hp			
• at 575/600 V rated value	7.5 hp			
contact rating of auxiliary contacts according to UL	A600 / Q600			
Short-circuit protection				
design of the fuse link				
<ul> <li>for short-circuit protection of the main circuit</li> </ul>				
— with type of coordination 1 required	gG NH 3NA, DIAZED 5SB, NEOZED 5SE: 35 A			
— with type of assignment 2 required	gG NH 3NA, DIAZED 5SB, NEOZED 5SE: 20 A			
<ul> <li>for short-circuit protection of the auxiliary switch</li> </ul>	fuse gG: 10 A			
required				
Installation/ mounting/ dimensions				
Installation/ mounting/ dimensions mounting position	+/-180° rotation possible on vertical mounting surface; can be tilted forward and backward by +/- 22.5° on vertical mounting surface			
	+/-180° rotation possible on vertical mounting surface; can be tilted forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail			
mounting position fastening method height	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm			
mounting position fastening method height width	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm			
mounting position fastening method height width depth	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm			
mounting position fastening method height width depth required spacing	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 0 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 0 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — at the side	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 0 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — backwards         — backwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 0 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — at the side         • for grounded parts         — backwards         — upwards         — ownwards         — at the side         • for wards         — upwards         — upwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — backwards         — backwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — at the side         • for grounded parts         — forwards         — at the side         • for grounded parts         — at the side         — backwards         — upwards         — at the side         — downwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — at the side         • for grounded parts         — forwards         — upwards         — at the side         — backwards         — upwards         — forwards         — at the side         — upwards         — upwards         — at the side	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — at the side         • for grounded parts         — forwards         — upwards         — downwards         — other side         • for grounded parts         — forwards         — backwards         — upwards         — ownwards         — at the side         — for live parts	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         - forwards         - backwards         - upwards         - downwards         - at the side         • for grounded parts         - forwards         - backwards         - upwards         - backwards         - forwards         - backwards         - ownwards         - forwards         - backwards         - at the side         - downwards         • for live parts         - forwards         - backwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         - forwards         - backwards         - upwards         - downwards         - at the side         • for grounded parts         - forwards         - backwards         - at the side         - forwards         - backwards         - forwards         - forwards         - forwards         - forwards         - forwards         - at the side         - downwards         • for live parts         - forwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — forwards         — forwards         — forwards         — backwards         — upwards         — backwards         — upwards         — upwards         • for live parts         — forwards         — backwards         — upwards         • for live parts         — upwards         — upwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — backwards         — upwards         — at the side         — downwards         • for live parts         — forwards         — backwards         — upwards         — downwards	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         — forwards         — backwards         — upwards         — downwards         — at the side         • for grounded parts         — forwards         — backwards         — upwards         — at the side         • for grounded parts         — forwards         — upwards         — backwards         — upwards         — ownwards         • for live parts         — forwards         — upwards         — downwards         • for live parts         — downwards         — upwards         — at the side	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         - forwards         - backwards         - upwards         - downwards         - at the side         • for grounded parts         - forwards         - backwards         - upwards         - at the side         - downwards         - backwards         - upwards         - backwards         - upwards         - at the side         - downwards         • for live parts         - forwards         - backwards         - upwards         - downwards         - at the side         - downwards         - at the side         - downwards         - at the side	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			
mounting position         fastening method         height         width         depth         required spacing         • with side-by-side mounting         - forwards         - backwards         - backwards         - upwards         - downwards         - at the side         • for grounded parts         - forwards         - backwards         - upwards         - at the side         - downwards         - at the side         - downwards         - for live parts         - forwards         - backwards         - upwards         - at the side         - downwards         - backwards         - upwards         - at the side         - downwards         - at the side         Connections/ Terminals         type of electrical connection	forward and backward by +/- 22.5° on vertical mounting surface screw and snap-on mounting onto 35 mm standard mounting rail 68 mm 90 mm 73 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm 6 mm			

					Screw-type terminals				
of magnet coil		lana	Screw	v-type terminals					
	conductor cross-sect	ions							
for main contacts									
— solid	andod					2.5 mm <sup>2</sup> ), 2x 4 mm <sup>2</sup>			
— solid or stra		opping				2,5 mm <sup>2</sup> ), 2x (0,5	4 mm~)		
— finely stranded with core end processing				5 1.5 mm²), 2x		2.5 mm²)			
at AWG cables for main contacts  type of connectable conductor cross-sections				2x (20 16), 2x (18 14)					
		ions							
for auxiliary contacts     solid or stranded			$2x (0.5 \pm 1.5 \text{ mm}^2) 2x (0.75 \pm 2.5 \text{ mm}^2)$						
— solid or stranded			2x (0.5 1.5 mm <sup>2</sup> ), 2x (0.75 2.5 mm <sup>2</sup> )						
— finely stranded with core end processing				2x (0.5 1.5 mm <sup>2</sup> ), 2x (0.75 2.5 mm <sup>2</sup> )					
at AWG cables for auxiliary contacts				2x (20 16), 2x (18 14)					
Safety related data		01104000	1.000	000	-				
	emand rate according t	o SN 31920	1 000	000					
proportion of danger			10.04						
	d rate according to SN		40 %						
_	nd rate according to SN		75 %						
failure rate [FIT] with lo 31920	failure rate [FIT] with low demand rate according to SN 31920			100 FIT					
T1 value for proof test interval or service life according to IEC 61508			20 y	20 y					
protection class IP on the front according to IEC 60529			IP20	IP20					
touch protection on	the front according to	IEC 60529	finger	-safe, for vertica	l conta	ct from the front			
Communication/ Proto	ocol								
product function bus	s communication		Yes						
protocol is supported A	AS-Interface protocol		No						
product function control	ol circuit interface with	IO link	No						
Certificates/ approvals	\$								
General Product Ap						Declaration of Conf	ormity		
oundrain roudor (p)	provu					Declaration of com	onnity		
(SP)	<u>Confirmation</u>	(UL) ut		EHC		CE EG-Konf.	UK CA		
Test Certificates		Marine / Ship	oping						
Special Test Certific- ate	<u>Type Test Certific-</u> ates/Test Report	ABS		BUREAU VERITAS			Lloyd's Register us		
Marine / Shipping				other		Railway	Dangerous Good		
PRS	RINA	RMARS RAMES		<u>Confirmation</u>	n	Vibration and Shock	<u>Transport Informa-</u> tion		
Further information									
https://www.siemens.c Industry Mall (Online	e ordering system) emens.com/mall/en/en/	-		3RA2316-8XB30	- <u>1BW4</u>				

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RA2316-8XB30-1BW4 Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3RA2316-8XB30-1BW4 Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3RA2316-8XB30-1BW4&lang=en Characteristic: Tripping characteristics, I<sup>2</sup>t, Let-through current https://support.industry.siemens.com/cs/ww/en/ps/3RA2316-8XB30-1BW4/char Further characteristics (e.g. electrical endurance, switching frequency) http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RA2316-8XB30-1BW4&objecttype=14&gridview=view1

last modified:

2/8/2022 🖸