SIEMENS

Data sheet 3RT1265-6AP36



vacuum contactor, AC-3 265 A, 132 kW / 400 V AC (50-60 Hz) / DC operation 220-240 V AC/DC auxiliary contacts 2 NO + 2 NC 3-pole, frame size S10 busbar connections drive: conventional

| product brand name | SIRIUS |
|---|----------------------------|
| product designation | Vacuum contactor |
| product type designation | 3RT12 |
| General technical data | |
| size of contactor | S10 |
| product extension | |
| function module for communication | No |
| auxiliary switch | Yes |
| power loss [W] for rated value of the current | |
| at AC in hot operating state | 36 W |
| at AC in hot operating state per pole | 12 W |
| without load current share typical | 8.2 W |
| insulation voltage | |
| of main circuit with degree of pollution 3 rated value | 1 000 V |
| of auxiliary circuit with degree of pollution 3 rated value | 500 V |
| surge voltage resistance | |
| of main circuit rated value | 8 kV |
| of auxiliary circuit rated value | 6 kV |
| maximum permissible voltage for safe isolation between coil and main contacts according to EN 60947-1 | 690 V |
| shock resistance at rectangular impulse | |
| • at AC | 8,5g / 5 ms, 4,2g / 10 ms |
| • at DC | 8,5g / 5 ms, 4,2g / 10 ms |
| shock resistance with sine pulse | |
| • at AC | 13,4g / 5 ms, 6,5g / 10 ms |
| • at DC | 13,4g / 5 ms, 6,5g / 10 ms |
| mechanical service life (switching cycles) | |
| of contactor typical | 10 000 000 |
| of the contactor with added electronically optimized auxiliary switch block typical | 5 000 000 |
| of the contactor with added auxiliary switch block typical | 10 000 000 |
| reference code according to IEC 81346-2 | Q |
| Substance Prohibitance (Date) | 05/01/2012 |
| Ambient conditions | |
| installation altitude at height above sea level maximum | 2 000 m |
| ambient temperature | |
| during operation | -25 +60 °C |
| during storage | -55 +80 °C |
| | |

| relative humidity minimum | 10 % |
|---|------------------------------|
| relative humidity at 55 °C according to IEC 60068-2-30 maximum | 95 % |
| lain circuit | |
| number of poles for main current circuit | 3 |
| number of NO contacts for main contacts | 3 |
| operating voltage | |
| at AC-3 rated value maximum | 1 000 V |
| at AC-3e rated value maximum | 1 000 V |
| operational current | |
| at AC-1 at 400 V at ambient temperature 40 °C rated value at AC-1 | 330 A |
| — up to 690 V at ambient temperature 40 $^{\circ}\text{C}$ rated value | 330 A |
| — up to 690 V at ambient temperature 60 $^{\circ}\text{C}$ rated value | 300 A |
| up to 1000 V at ambient temperature 40 °C rated value | 330 A |
| — up to 1000 V at ambient temperature 60 °C rated value | 300 A |
| • at AC-3 | 005.4 |
| — at 400 V rated value | 265 A |
| — at 500 V rated value | 265 A |
| — at 690 V rated value | 265 A |
| — at 1000 V rated value | 265 A |
| • at AC-3e | |
| — at 400 V rated value | 265 A |
| — at 500 V rated value | 265 A |
| — at 690 V rated value | 265 A |
| — at 1000 V rated value | 265 A |
| at AC-4 at 400 V rated valueat AC-6a | 230 A |
| up to 230 V for current peak value n=20 rated value | 265 A |
| up to 400 V for current peak value n=20 rated value | 265 A |
| — up to 500 V for current peak value n=20 rated value | 265 A |
| — up to 690 V for current peak value n=20 rated value | 265 A |
| up to 1000 V for current peak value n=20 rated value at AC-6a | 265 A |
| — up to 230 V for current peak value n=30 rated value | 209 A |
| up to 400 V for current peak value n=30 rated value | 209 A |
| — up to 500 V for current peak value n=30 rated value | 209 A |
| — up to 690 V for current peak value n=30 rated value | 209 A |
| — up to 1000 V for current peak value n=30 rated value minimum cross-section in main circuit at maximum AC-1 | 209 A 185 mm ² |
| rated value operational current for approx. 200000 operating | 100 11111 |
| cycles at AC-4 | |
| at 400 V rated value | 115 A |
| • at 690 V rated value | 115 A |
| operating power | |
| • at AC-3 | |
| — at 230 V rated value | 75 kW |
| — at 400 V rated value | 132 kW |

| . = 0.0 \ / / / / / / | 400 1111 |
|--|---|
| — at 500 V rated value | 160 kW |
| — at 690 V rated value | 250 kW |
| — at 1000 V rated value | 355 kW |
| • at AC-3e | |
| — at 230 V rated value | 75 kW |
| — at 400 V rated value | 132 kW |
| — at 500 V rated value | 160 kW |
| — at 690 V rated value | 250 kW |
| — at 1000 V rated value | 355 kW |
| operating power for approx. 200000 operating cycles at AC-4 | |
| at 400 V rated value | 65 kW |
| at 690 V rated value | 112 kW |
| operating apparent power at AC-6a | |
| up to 230 V for current peak value n=20 rated value | 100 000 kVA |
| up to 400 V for current peak value n=20 rated value | 180 000 VA |
| up to 500 V for current peak value n=20 rated value | 220 000 VA |
| up to 690 V for current peak value n=20 rated value | 310 000 VA |
| up to 1000 V for current peak value n=20 rated value | 450 000 VA |
| operating apparent power at AC-6a | |
| • up to 230 V for current peak value n=30 rated value | 80 000 VA |
| • up to 400 V for current peak value n=30 rated value | 140 000 VA |
| up to 500 V for current peak value n=30 rated value | 180 000 VA |
| up to 690 V for current peak value n=30 rated value | 250 000 VA |
| up to 1000 V for current peak value n=30 rated value | 360 000 VA |
| no-load switching frequency | |
| • at AC | 2 000 1/h |
| • at DC | 2 000 1/h |
| operating frequency | |
| • at AC-1 maximum | 750 1/h |
| • at AC-2 maximum | 250 1/h |
| • at AC-3 maximum | 750 1/h |
| at AC-3e maximum | 750 1/h |
| • at AC-4 maximum | 250 1/h |
| Control circuit/ Control | |
| type of voltage of the control supply voltage | AC/DC |
| control supply voltage at AC | |
| at 50 Hz rated value | 220 240 V |
| at 60 Hz rated value | 220 240 V |
| control supply voltage at DC | |
| • rated value | 220 240 1/ |
| • lated value | 220 240 V |
| operating range factor control supply voltage rated value of magnet coil at DC | 220 240 V |
| operating range factor control supply voltage rated | 0.8 |
| operating range factor control supply voltage rated value of magnet coil at DC | |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value | 0.8 |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated | 0.8 |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC | 0.8 1.1 |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz | 0.8 1.1 0.8 1.1 |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz • at 60 Hz | 0.8 1.1 0.8 1.1 0.8 1.1 |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz • at 60 Hz design of the surge suppressor | 0.8 1.1 0.8 1.1 0.8 1.1 |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz • at 60 Hz design of the surge suppressor apparent pick-up power of magnet coil at AC | 0.8 1.1 0.8 1.1 0.8 1.1 with varistor |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz • at 60 Hz design of the surge suppressor apparent pick-up power of magnet coil at AC • at 50 Hz | 0.8 1.1 0.8 1.1 0.8 1.1 with varistor |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz • at 60 Hz design of the surge suppressor apparent pick-up power of magnet coil at AC • at 50 Hz • at 60 Hz | 0.8 1.1 0.8 1.1 0.8 1.1 with varistor |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz • at 60 Hz design of the surge suppressor apparent pick-up power of magnet coil at AC • at 50 Hz • at 60 Hz inductive power factor with closing power of the coil | 0.8 1.1 0.8 1.1 0.8 1.1 with varistor 590 VA 590 VA |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz • at 60 Hz design of the surge suppressor apparent pick-up power of magnet coil at AC • at 50 Hz • at 60 Hz inductive power factor with closing power of the coil • at 50 Hz | 0.8 1.1 0.8 1.1 0.8 1.1 with varistor 590 VA 590 VA |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz • at 60 Hz design of the surge suppressor apparent pick-up power of magnet coil at AC • at 50 Hz • at 60 Hz inductive power factor with closing power of the coil • at 50 Hz • at 60 Hz | 0.8 1.1 0.8 1.1 0.8 1.1 with varistor 590 VA 590 VA |
| operating range factor control supply voltage rated value of magnet coil at DC • initial value • full-scale value operating range factor control supply voltage rated value of magnet coil at AC • at 50 Hz • at 60 Hz design of the surge suppressor apparent pick-up power of magnet coil at AC • at 50 Hz • at 60 Hz inductive power factor with closing power of the coil • at 50 Hz • at 60 Hz apparent holding power of magnet coil at AC | 0.8 1.1 0.8 1.1 0.8 1.1 with varistor 590 VA 590 VA 0.9 0.9 |

| inductive power factor with the holding power of the coil | |
|---|---|
| • at 50 Hz | 0.0 |
| • at 50 Hz • at 60 Hz | 0.9 0.9 |
| | |
| closing power of magnet coil at DC | 700 W |
| holding power of magnet coil at DC | 8.2 W |
| closing delay | |
| • at AC | 30 95 ms |
| • at DC | 30 95 ms |
| opening delay | |
| • at AC | 40 80 ms |
| • at DC | 40 80 ms |
| arcing time | 10 15 ms |
| control version of the switch operating mechanism | Standard A1 - A2 |
| Auxiliary circuit | |
| number of NC contacts for auxiliary contacts | 2 |
| instantaneous contact | |
| number of NO contacts for auxiliary contacts instantaneous contact | 2 |
| operational current at AC-12 maximum | 10 A |
| operational current at AC-15 | |
| • at 230 V rated value | 6 A |
| at 400 V rated value | 3 A |
| • at 500 V rated value | 2 A |
| at 690 V rated value | 1 A |
| operational current at DC-12 | |
| • at 24 V rated value | 10 A |
| at 48 V rated value | 6 A |
| at 60 V rated value | 6 A |
| at 110 V rated value | 3 A |
| • at 125 V rated value | 2 A |
| at 220 V rated value | 1 A |
| at 600 V rated value | 0.15 A |
| operational current at DC-13 | |
| at 24 V rated value | 10 A |
| at 48 V rated value | 2 A |
| at 60 V rated value | 2 A |
| at 110 V rated value | 1 A |
| at 176 V rated value at 125 V rated value | 0.9 A |
| at 123 V rated value at 220 V rated value | 0.3 A |
| at 600 V rated value | 0.1 A |
| | |
| contact reliability of auxiliary contacts | 1 faulty switching per 100 million (17 V, 1 mA) |
| UL/CSA ratings | |
| full-load current (FLA) for 3-phase AC motor | 040.4 |
| • at 480 V rated value | 240 A |
| at 600 V rated value | 242 A |
| yielded mechanical performance [hp] | |
| • for 3-phase AC motor | |
| — at 200/208 V rated value | 75 hp |
| — at 220/230 V rated value | 100 hp |
| — at 460/480 V rated value | 200 hp |
| — at 575/600 V rated value | 250 hp |
| contact rating of auxiliary contacts according to UL | A600 / Q600 |
| Short-circuit protection | |
| design of the fuse link | |
| for short-circuit protection of the main circuit | |
| with type of coordination 1 required | gG: 500 A (690 V, 100 kA) |
| — with type of assignment 2 required | gG: 500 A (690 V, 100 kA), aM: 400 A (690 V, 50 kA), BS88: 450 A (415 V, 50 kA) |
| for short-circuit protection of the auxiliary switch required | gG: 10 A (500 V, 1 kA) |
| 1 | |

| mounting position | +/-22,5° rotation possible on vertical mounting surface; can be tilted |
|--|--|
| mounting position | forward and backward by +/- 22.5° on vertical mounting surface; standing, on horizontal mounting surface |
| fastening method | screw fixing |
| side-by-side mounting | Yes |
| height | 210 mm |
| width | 145 mm |
| depth | 206 mm |
| required spacing | |
| with side-by-side mounting | |
| — forwards | 20 mm |
| — upwards | 10 mm |
| — downwards | 10 mm |
| — at the side | 0 mm |
| • for grounded parts | |
| — forwards | 20 mm |
| — upwards | 10 mm |
| — upwards — at the side | 10 mm |
| — at the side — downwards | 10 mm |
| | TO THILL |
| • for live parts | 20 mm |
| — forwards | 20 mm |
| — upwards | 10 mm |
| — downwards | 10 mm |
| — at the side | 10 mm |
| Connections/ Terminals | |
| type of electrical connection | |
| for main current circuit | Connection bar |
| for auxiliary and control circuit | screw-type terminals |
| at contactor for auxiliary contacts | Screw-type terminals |
| of magnet coil | Screw-type terminals |
| width of connection bar | 25 mm |
| thickness of connection bar | 6 mm |
| diameter of holes | 11 mm |
| number of holes | 1 |
| type of connectable conductor cross-sections | |
| at AWG cables for main contacts | 2/0 500 kcmil |
| connectable conductor cross-section for main contacts | |
| stranded | 70 240 mm² |
| connectable conductor cross-section for auxiliary contacts | |
| solid or stranded | 0.5 4 mm² |
| finely stranded with core end processing | 0.5 2.5 mm² |
| type of connectable conductor cross-sections | |
| for auxiliary contacts | |
| — solid | 2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²), max. 2x (0.75 4 mm²) |
| — solid or stranded | 2x (0,5 1,5 mm²), 2x (0,75 2,5 mm²), max. 2x (0,75 4 mm²) |
| finely stranded with core end processing | 2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²) |
| at AWG cables for auxiliary contacts | 2x (20 16), 2x (18 14), 1x 12 |
| AWG number as coded connectable conductor cross section | |
| for auxiliary contacts | 18 14 |
| afety related data | |
| product function | |
| mirror contact according to IEC 60947-4-1 | Yes |
| • positively driven operation according to IEC 60947- 5-1 | No |
| protection class IP on the front according to IEC 60529 | IP00; IP20 with box terminal/cover |
| | |

suitability for use

• safety-related switching OFF

Yes

Certificates/ approvals

General Product Approval



Confirmation





<u>KC</u>



| | Functional |
|-----|-------------------------------|
| EMC | Safety/Safety of Machinery |

Declaration of Conformity

Test Certificates



Type Examination Certificate





Special Test Certificate

Type Test Certificates/Test Report

Marine / Shipping











Confirmation

other

other

Railway

Miscellaneous

Confirmation

Special Test Certificate

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RT1265-6AP36

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RT1265-6AP36

 $Service \& Support \ (Manuals, Certificates, Characteristics, FAQs, ...)$

https://support.industry.siemens.com/cs/ww/en/ps/3RT1265-6AP36

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ EPLAN\ macros,\ ...)$

 $\underline{\text{http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RT1265-6AP36\&lang=enderse$

Characteristic: Tripping characteristics, I²t, Let-through current

https://support.industry.siemens.com/cs/ww/en/ps/3RT1265-6AP36/char

Further characteristics (e.g. electrical endurance, switching frequency)

http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RT1265-6AP36&objecttype=14&gridview=view1

last modified:

3/24/2022