SIEMENS

Data sheet

3RT2038-1AV04



Power contactor, AC-3 80 A, 37 kW / 400 V 2 NO + 2 NC, 400 V AC, 50 Hz 3-pole, size S2 screw terminals

· · · ·	
product brand name	SIRIUS
product designation	Power contactor
product type designation	3RT2
General technical data	
size of contactor	S2
product extension	
 function module for communication 	No
auxiliary switch	No
power loss [W] for rated value of the current	
 at AC in hot operating state 	17.1 W
 at AC in hot operating state per pole 	5.7 W
without load current share typical	16 W
insulation voltage	
 of main circuit with degree of pollution 3 rated value 	690 V
 of auxiliary circuit with degree of pollution 3 rated value 	690 V
surge voltage resistance	
 of main circuit rated value 	6 kV
 of auxiliary circuit rated value 	6 kV
maximum permissible voltage for safe isolation between coil and main contacts according to EN 60947-1	400 V
shock resistance at rectangular impulse	
• at AC	9.8g / 5 ms, 6.5g / 10 ms
shock resistance with sine pulse	
• at AC	15.3g / 5 ms, 10.1g / 10 ms
mechanical service life (switching cycles)	
 of contactor typical 	10 000 000
 of the contactor with added electronically optimized auxiliary switch block typical 	5 000 000
 of the contactor with added auxiliary switch block typical 	10 000 000
reference code according to IEC 81346-2	Q
Substance Prohibitance (Date)	10/01/2014
Ambient conditions	
installation altitude at height above sea level maximum	2 000 m
ambient temperature	
during operation	-25 +60 °C
during storage	-55 +80 °C
relative humidity minimum	10 %
relative humidity at 55 °C according to IEC 60068-2-30 maximum	95 %

Main circuit	
number of poles for main current circuit	3
number of NO contacts for main contacts	3
operating voltage	
 at AC-3 rated value maximum 	690 V
 at AC-3e rated value maximum 	690 V
operational current	
 at AC-1 at 400 V at ambient temperature 40 °C rated value 	90 A
• at AC-1	
 — up to 690 V at ambient temperature 40 °C rated value 	90 A
— up to 690 V at ambient temperature 60 °C rated value	80 A
• at AC-3	
— at 400 V rated value	80 A
— at 500 V rated value	80 A
— at 690 V rated value	58 A
• at AC-3e	
— at 400 V rated value	80 A
— at 500 V rated value	80 A
— at 690 V rated value	58 A
• at AC-4 at 400 V rated value	55 A
at AC-5a up to 690 V rated value	79.2 A
• at AC-5b up to 400 V rated value	66.4 A
• at AC-6a	
 up to 230 V for current peak value n=20 rated value 	70 A
 up to 400 V for current peak value n=20 rated value 	70 A
 — up to 500 V for current peak value n=20 rated value 	70 A
— up to 690 V for current peak value n=20 rated value	58 A
 at AC-6a up to 230 V for current peak value n=30 rated value 	46.7 A
 up to 400 V for current peak value n=30 rated value 	46.7 A
 — up to 500 V for current peak value n=30 rated value 	46.7 A
— up to 690 V for current peak value n=30 rated value	46.7 A
minimum cross-section in main circuit at maximum AC-1 rated value operational current for approx. 200000 operating	35 mm²
cycles at AC-4	
at 400 V rated value	30 A
• at 690 V rated value	24 A
operational current	
• at 1 current path at DC-1	
— at 24 V rated value	55 A
— at 110 V rated value	4.5 A
— at 220 V rated value	1A
— at 440 V rated value	0.4 A
— at 600 V rated value	0.25 A
with 2 current paths in series at DC-1	
- at 24 V rated value	55 A
	55 A 45 A
— at 110 V rated value	
— at 220 V rated value	5 A
— at 440 V rated value	1A
— at 600 V rated value	0.8 A
 with 3 current paths in series at DC-1 	

— at 24 V rated value	55 A
— at 110 V rated value	55 A
— at 220 V rated value	45 A
— at 440 V rated value	2.9 A
— at 600 V rated value	1.4 A
 at 1 current path at DC-3 at DC-5 	
— at 24 V rated value	35 A
— at 110 V rated value	2.5 A
— at 220 V rated value	1 A
— at 440 V rated value	0.1 A
— at 600 V rated value	0.06 A
 with 2 current paths in series at DC-3 at DC-5 	
— at 24 V rated value	55 A
— at 110 V rated value	25 A
— at 220 V rated value	5 A
— at 440 V rated value	0.27 A
— at 600 V rated value	0.16 A
 with 3 current paths in series at DC-3 at DC-5 	
— at 24 V rated value	55 A
— at 110 V rated value	55 A
— at 220 V rated value	25 A
— at 440 V rated value	0.6 A
— at 600 V rated value	0.35 A
operating power	
at AC-2 at 400 V rated value	37 kW
• at AC-3	
— at 230 V rated value	22 kW
— at 400 V rated value	37 kW
— at 500 V rated value	37 kW
— at 690 V rated value	45 kW
• at AC-3e	
- at 230 V rated value	22 kW
— at 200 V rated value	37 kW
— at 500 V rated value	
	37 kW
at 690 V rated value	45 kW
operating power for approx. 200000 operating cycles at AC-4	
 at 400 V rated value 	15.8 kW
at 690 V rated value	21.8 kW
operating apparent power at AC-6a	
up to 230 V for current peak value n=20 rated value	27.8 kVA
• up to 400 V for current peak value n=20 rated value	48.4 kVA
• up to 500 V for current peak value n=20 rated value	60.6 kVA
• up to 690 V for current peak value n=20 rated value	69.3 kVA
operating apparent power at AC-6a	
• up to 230 V for current peak value n=30 rated value	18.6 kVA
• up to 200 V for current peak value n=30 rated value	32.3 kVA
 up to 400 V for current peak value n=30 rated value up to 500 V for current peak value n=30 rated value 	40.4 kVA
	40.4 KVA 55.8 kVA
up to 690 V for current peak value n=30 rated value short-time withstand current in cold operating state	
up to 40 °C	
 limited to 1 s switching at zero current maximum 	1 298 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 5 s switching at zero current maximum 	898 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 10 s switching at zero current maximum 	640 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 30 s switching at zero current maximum 	414 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 60 s switching at zero current maximum 	333 A; Use minimum cross-section acc. to AC-1 rated value
no-load switching frequency	
• at AC	5 000 1/h
operating frequency	
• at AC-1 maximum	700 1/h
• at AC-2 maximum	350 1/h
■ at AU-2 maximum	000 1/11

a at AC 2 monitories	500 4/h
• at AC-3 maximum	500 1/h
• at AC-3e maximum	500 1/h
• at AC-4 maximum	150 1/h
Control circuit/ Control	
type of voltage of the control supply voltage	AC
control supply voltage at AC	
at 50 Hz rated value	400 V
operating range factor control supply voltage rated	
value of magnet coil at AC	0.0 4.4
• at 50 Hz	0.8 1.1
apparent pick-up power of magnet coil at AC	100.1/4
• at 50 Hz	190 VA
inductive power factor with closing power of the coil	0.72
• at 50 Hz	0.72
apparent holding power of magnet coil at AC	40.1/4
• at 50 Hz	16 VA
inductive power factor with the holding power of the coil	
• at 50 Hz	0.37
closing delay	
• at AC	10 80 ms
opening delay	
• at AC	10 18 ms
arcing time	10 20 ms
control version of the switch operating mechanism	Standard A1 - A2
Auxiliary circuit	
number of NC contacts for auxiliary contacts	2
instantaneous contact	
number of NO contacts for auxiliary contacts	2
instantaneous contact	10 A
operational current at AC-12 maximum	
operational current at AC-15	6.4
 at 230 V rated value at 400 V rated value 	6 A 3 A
at 400 V rated value at 500 V rated value	2 A
at 500 V rated value at 690 V rated value	2 A 1 A
operational current at DC-12 • at 24 V rated value	10 A
at 24 V rated value at 48 V rated value	6 A
at 48 v rated value at 60 V rated value	6 A
at 60 V rated value at 110 V rated value	6 A 3 A
at 125 V rated value	2 A
at 125 V rated value at 220 V rated value	2 A 1 A
at 220 V rated value at 600 V rated value	0.15 A
operational current at DC-13	
• at 24 V rated value	6 4
	6 A 2 A
at 48 V rated value	2 A 2 A
at 60 V rated value	
at 110 V rated value	1 A
at 125 V rated value	0.9 A 0.3 A
at 220 V rated value	
at 600 V rated value	0.1 A
contact reliability of auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)
UL/CSA ratings	
full-load current (FLA) for 3-phase AC motor	65 A
at 480 V rated value	65 A
at 600 V rated value	62 A
yielded mechanical performance [hp]	
for single-phase AC motor	5 hz
— at 110/120 V rated value	5 hp 15 hp
— at 230 V rated value	

• for 3-phase AC motor	
 Ior 3-phase AC motor — at 200/208 V rated value 	20 hp
— at 220/200 V rated value	25 hp
— at 460/480 V rated value	50 hp
— at 575/600 V rated value	60 hp
contact rating of auxiliary contacts according to UL	A600 / Q600
Short-circuit protection	
design of the fuse link	
for short-circuit protection of the main circuit	
- with type of coordination 1 required	gG: 250 A (690 V, 100 kA), aM: 160 A (690 V, 100 kA), BS88: 200 A (415 V, 80 kA)
— with type of assignment 2 required	gG: 160A (690V,100kA), aM: 80A (690V,100kA), BS88: 125A (415V,80kA)
 for short-circuit protection of the auxiliary switch required 	gG: 10 A (500 V, 1 kA)
Installation/ mounting/ dimensions	
mounting position	+/-180° rotation possible on vertical mounting surface; can be tilted
	forward and backward by +/- 22.5° on vertical mounting surface
fastening method	screw and snap-on mounting onto 35 mm standard mounting rail according to DIN EN 60715
side-by-side mounting	Yes
height	114 mm
width	55 mm
depth	174 mm
required spacing	
 with side-by-side mounting — forwards 	10 mm
	10 mm
— upwards — downwards	10 mm
— at the side	0 mm
for grounded parts	0 mm
- forwards	10 mm
— upwards	10 mm
— at the side	6 mm
— downwards	10 mm
• for live parts	
— forwards	10 mm
— upwards	10 mm
— downwards	10 mm
— at the side	6 mm
Connections/ Terminals	
type of electrical connection	
for main current circuit	screw-type terminals
for auxiliary and control circuit	screw-type terminals
 at contactor for auxiliary contacts 	Screw-type terminals
 of magnet coil 	Screw-type terminals
type of connectable conductor cross-sections	
for main contacts	
— solid or stranded	2x (1 35 mm²), 1x (1 50 mm²)
— finely stranded with core end processing	2x (1 25 mm ²), 1x (1 35 mm ²)
 at AWG cables for main contacts 	2x (18 2), 1x (18 1)
connectable conductor cross-section for main	
contacts	
 finely stranded with core end processing 	1 35 mm²
connectable conductor cross-section for auxiliary contacts	
 solid or stranded 	0.5 2.5 mm ²
 finely stranded with core end processing 	0.5 2.5 mm²
type of connectable conductor cross-sections	
 for auxiliary contacts 	
— solid or stranded	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)

Awg number as coded connectable conductor cross	 finely stranded with core end processing at AWG cables for auxiliary contacts 		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²) 2x (20 16), 2x (18 14)				
e for auxiliary contacts 20 14 Statey related data Improve related addition of the control of the C 60947 - 1. No - positive finance according to SN 31920 1000 000 Propertion of dangerous Failures 40 %. - with high demand rate according to SN 31920 73 %. - with high demand rate according to SN 31920 20 y - with high demand rate according to SN 31920 20 y - file of state internal or service life according to SN 31920 20 y - file of state internal or service life according to EC 60927 1000 FIT - file of state internal or service life according to EC 60927 120 - 1100 FIT - truck protection on the front according to EC 60927 120 - 1100 FIT - stately-related switching OFF Yes - control contact from the front according to EC 60927 1000 FIT - stately-related switching OFF Yes - control contact from the front according to EC 60927 1000 FIT - stately-related switching OFF Yes - file of file officates Declaration of Conformity Test Contificates File officates Declaration of Conformity Test Contificates File officates Declaration of Conformity Speci	AWG number as coo		luctor cross				
Safety related data product function inform contrast according to IEC 60947-4.1 positively driven operation according to SN 31920 inform contrast according to SN 31920 information contrast according to IEC 60529 information do contormity information contrast according to IEC 60529 information do contormity information contrast according to IEC 60529 information do contormity information contrast according to IEC 60529 information do contormity information contrast according to IEC 60529 information contrast according to IEC 60529 information do contormity i			18 1				
product function • miror contact according to EC 60947-11 • positively driven operation according to EO 60947- 51 Yes No 100 due with high demand rate according to SN 31920 1000 000 Proportion of dargerous failures 40 % • with low demand rate according to SN 31920 1000 000 Proportion of dargerous failures 40 % • with high demand rate according to SN 31920 40 % • with low demand rate according to SN 31920 20 y • protection class IP on the front according to IEC 60529 20 y Functional state state dimension (FT) Yes Outer protection class IP on the front according to IEC 60529 Ingen-safe, for vertical contact from the front subbility for use Confirmation Confirmation • safety/Patriets switching OFF Yes Confirmation Confirmation Confirmation Seevel State State State State St	 for auxiliary cor 	ntacts		20 14			
product function • miror contact according to EC 60947-11 • positively driven operation according to EO 60947- 51 Yes No 100 due with high demand rate according to SN 31920 1000 000 Proportion of dargerous failures 40 % • with low demand rate according to SN 31920 1000 000 Proportion of dargerous failures 40 % • with high demand rate according to SN 31920 40 % • with low demand rate according to SN 31920 20 y • protection class IP on the front according to IEC 60529 20 y Functional state state dimension (FT) Yes Outer protection class IP on the front according to IEC 60529 Ingen-safe, for vertical contact from the front subbility for use Confirmation Confirmation • safety/Patriets switching OFF Yes Confirmation Confirmation Confirmation Seevel State State State State St	Safety related data						
 infore contrast according to EC 60947-11 softwide when operation according to SN 31920 B10 value with high demand rate according to SN 31920 in thin whermad rate according to EC 60529 in the rotat according to EC 60529<td>-</td><td></td><td></td><td></td><td></td><td></td>	-						
 e) epidevely driven operation according to EC 60947- 5-1 B10 value with high demand rate according to SN 31920 e) with low demand rate according to SN 31920 e) with low demand rate according to SN 31920 e) with low demand rate according to SN 31920 e) with low demand rate according to SN 31920 e) with low demand rate according to SN 31920 e) with low demand rate according to SN 31920 e) with low demand rate according to SN 31920 e) with low demand rate according to SN 31920 e) with low demand rate according to IEC g) P20 <lig) <="" li="" p20=""> <lig) <="" li="" p20=""></lig)></lig)>		according to IEC 60947	-4-1	Yes			
5-1 Continuation B10 value with high demand rate according to SN 31920 1000 000 Proportion of dangerous failures 40 % • with high demand rate according to SN 31920 73 % failure rate [FT] with low demand rate according to SN 31920 73 % failure rate [FT] with low demand rate according to SN 31920 73 % failure rate [FT] with low demand rate according to IEC 00520 100 FT gased of the front according to IEC 00520 100 FT stafely related switching OFF Yes • safely-related switching OFF Yes • safely-related switching OFF Yes certificated approval Confirmation General Product Approval Confirmation EMC Safely/Safety of Machinery Declaration of Conformity Test Certificates figs Low Examination Certificates Saceial Test Certificates figs Low Examination Certificates Saceial Test Certificates figs Low Examination Certificates Saceial Test Certificates figs Low Examination Saceial Test Certificates Saceial Test Certificates figs Safety/Safety of Saceial							
proportion of dangerous failures 40 % • with high demand rate according to SN 31920 73 % failure rate [FIT] with low demand rate according to SN 31920 73 % failure for proof test interval or service life according to IEC 60529 20 y protection cales IP on the front according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 </td <td></td> <td></td> <td></td> <td colspan="4">NO</td>				NO			
proportion of dangerous failures 40 % • with high demand rate according to SN 31920 73 % failure rate [FIT] with low demand rate according to SN 31920 73 % failure for proof test interval or service life according to IEC 60529 20 y protection cales IP on the front according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 outel high demand rate according to IEC 60529 1920 </td <td>B10 value with high d</td> <td>emand rate according</td> <td>to SN 31920</td> <td colspan="4">1 000 000</td>	B10 value with high d	emand rate according	to SN 31920	1 000 000			
• with how demand rate according to SN 31920 40 % • with high demand rate according to SN 31920 73 % failure rate [FT] with low demand rate according to SN 31920 20 y Fillure rate [FT] with low demand rate according to SN 31920 20 y Fillure rate [FT] with low demand rate according to SN 31920 20 y Fillure rate [FT] with low demand rate according to IEC 60520 IP20 Fillure rate [FT] with low demand rate according to IEC 60520 IP20 Fillure rate [FT] with low demand rate according to IEC 60520 IP20 suitability for use .	-						
 with high demand rate according to SN 31920 Satisfy rate (FT) with low demand rate according to SN 31920 Thi value for proof test interval or service life according to EC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC 0029 Protection class IP on the front according to IEC			31920	40 %			
failure rate [FIT] with low demand rate according to SN 31520 100 FIT 11 value for proof test interval or service life according to IEC 60529 20 y Protection class IP on the front according to IEC 60529 IP20 Sutballity for use rest-safe, for vertical contact from the front • safely-related switching OFF Yes Confirmation Confirmation EMC Functional safely/failed switching OFF Confirmation Confirmation Confirmation <t< td=""><td></td><td>-</td><td></td><td></td><td></td><td></td></t<>		-					
31920 20 y IFC 61508 protection class IP on the front according to IEC 6052 0000 protection on the front according to IEC 6052 inger-safe, for vertical contact from the front suitability for use yes • safely-related switching OFF yes Confirmation Confirmation General Product Approval Confirmation Confirmation Confirmation Safety/Safety of Confirmation Declaration of Conformity Confirmation Confirmation	-	-					
IEC 6106 IP20 protection diss IP on the front according to IEC 60529 Irger-safe, for vertical contact from the front suitability for use Yes • safely-related switching OFF Yes Centritates/ approvals General Product Approval General Product Approval ECC EMC Functional Safety/Safety of RCM Declaration of Conformity Tost Certificates EMC Irger Examination Certificate Epice Examination Lts Epice Examination Lts Epice Examination Lts EXEC Irger Examination Certificate Epice Examination Lts Epice Examination Lts Epice Examination Lts Epice Examination Lts Examination Safety Function and Shock Confirmation Lts Con	31920			100111			
60529 rouch protection on the front according to IEC 60529 • safely-related switching OFF Yes Confirmation Safely-related switching OFF Yes Confirmation Safely-related switching OFF Confirmation Safely-related switching OFF Yes Confirmation Safely-related switching OFF Confirmation Safely-related switching OFF Confirmation Safely-related switching OFF Safely-related switching OFF Safely-related switching OFF Confirmation Safely-related switching OFF Terretional Safely-related switching OFF Confirmation Safely-related switching OFF Terretional Safely-related switching OFF Type Teart Centific- tate Special Test Centific ates Special Test Centific ates Speci		t interval or service life	according to	20 у			
suitability for use safety-related switching OFF Vers Contributed Approvals General Product Approval Confirmation Confirmat		on the front according	to IEC	IP20			
e safety-related switching OFF Contributed approvals Condimination Confimiation Co	touch protection on	the front according to	DIEC 60529	finger-safe, for vertical conta	act from the front		
Certificates / approvals General Product Approval Image: Confirmation Image: Confirmatio	suitability for use						
General Product Approval Special Test Certificates KC Efficience EMC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates EMC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates Image: Certificate Type Examination Certificate Image: Certificate Special Test Certificates Type Test Certificates Marine / Shipping Image: Certificate Image: Certificate Image: Certificate Image: Certificate Image: Certificate Marine / Shipping Image: Confirmation Image: Confirmation Image: Confirmation Image: Confirmation Image: Confirmation Image: Confirmation Confirmation Confirmation Image: Confirmation Image: Confirmation Image: Confirmation Further Information- and Downloadcenter (Catalogs, Brochures,) Image: Confirmation Image: Confirmation Image: Confirmation Image: Confirmation	 safety-related s 	witching OFF		Yes			
General Product Approval Special Test Certificates KC Efficience EMC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates EMC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates Image: Certificate Type Examination Certificate Image: Certificate Special Test Certificates Type Test Certificates Marine / Shipping Image: Certificate Image: Certificate Image: Certificate Image: Certificate Image: Certificate Marine / Shipping Image: Confirmation Image: Confirmation Image: Confirmation Image: Confirmation Image: Confirmation Image: Confirmation Confirmation Confirmation Image: Confirmation Image: Confirmation Image: Confirmation Further Information- and Downloadcenter (Catalogs, Brochures,) Image: Confirmation Image: Confirmation Image: Confirmation Image: Confirmation	Certificates/ approval	s					
EMC Safety/Safety of Machinery Declaration of Conformity Test Certificates Image: Declaration of Conformity Special Test Certificate Special Test Certificate Type Test Certificate Image: Declaration of Conformity Image: Declaration of Conformity Image: Declaration of Conformity Special Test Certificate Type Test Certificate Image: Declaration of Conformity Image: Declaration of Conformity Image: Declaration of Conformity Special Test Certificate Type Test Certificate Test Certificate Type Test Certificate <tht< th=""><th>(Sfr</th><th><u>Confirmation</u></th><th></th><th></th><th>KC</th><th>EHC</th></tht<>	(Sfr	<u>Confirmation</u>			KC	EHC	
Image: Certificate Image: Certificate <th ce<="" colds:="" th=""><th>EMC</th><th>Safety/Safety of</th><th>Declaration of</th><th>of Conformity</th><th>Test Certificates</th><th></th></th>	<th>EMC</th> <th>Safety/Safety of</th> <th>Declaration of</th> <th>of Conformity</th> <th>Test Certificates</th> <th></th>	EMC	Safety/Safety of	Declaration of	of Conformity	Test Certificates	
Image: Second	RCM		UK CA	CE EG-Konf.			
Marine / Shipping other Railway Dangerous Good Image: State Stat	Marine / Shipping						
Confirmation Confirmation Vibration and Shock Transport Information Eurther information Information- and Downloadcenter (Catalogs, Brochures,) https://www.siemens.com/ic10	ABS	BUREAU VERITAS		Lloyd's Register urs	PRS	RINA	
Further information Information- and Downloadcenter (Catalogs, Brochures,) https://www.siemens.com/ic10	Marine / Shipping	other		Railway	Dangerous Good		
Information- and Downloadcenter (Catalogs, Brochures,) https://www.siemens.com/ic10	KARS	<u>Confirmation</u>	Confirmatio	on <u>Vibration and Shock</u>			
https://www.siemens.com/ic10	Further information						
	https://www.siemens.	<u>com/ic10</u>	gs, Brochures,.)			

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RT2038-1AV04

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RT2038-1AV04

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3RT2038-1AV04

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RT2038-1AV04&lang=en

Characteristic: Tripping characteristics, I²t, Let-through current

https://support.industry.siemens.com/cs/ww/en/ps/3RT2038-1AV04/char

Further characteristics (e.g. electrical endurance, switching frequency) http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RT2038-1AV04&objecttype=14&gridview=view1



last modified:

2/15/2022 🖸