SIEMENS

Data sheet

3RT2036-1AF00



power contactor, AC-3 51 A, 22 kW / 400 V 1 NO + 1 NC, 110 V AC, 50 Hz, 3-pole, size S2, screw terminal

product brand name	SIRIUS		
product designation	Power contactor		
product type designation	3RT2		
General technical data			
size of contactor	S2		
product extension			
 function module for communication 	No		
auxiliary switch	Yes		
power loss [W] for rated value of the current			
 at AC in hot operating state 	12 W		
 at AC in hot operating state per pole 	4 W		
 without load current share typical 	16 W		
insulation voltage			
 of main circuit with degree of pollution 3 rated value 	690 V		
 of auxiliary circuit with degree of pollution 3 rated value 	690 V		
surge voltage resistance			
 of main circuit rated value 	6 kV		
 of auxiliary circuit rated value 	6 kV		
maximum permissible voltage for safe isolation between coil and main contacts according to EN 60947-1	400 V		
shock resistance at rectangular impulse			
• at AC	11.8g / 5 ms, 7.4g / 10 ms		
shock resistance with sine pulse			
• at AC	18.5g / 5 ms, 11.6g / 10 ms		
mechanical service life (switching cycles)			
 of contactor typical 	10 000 000		
 of the contactor with added electronically optimized auxiliary switch block typical 	5 000 000		
 of the contactor with added auxiliary switch block typical 	10 000 000		
reference code according to IEC 81346-2	Q		
Substance Prohibitance (Date)	10/01/2014		
Ambient conditions			
installation altitude at height above sea level maximum	2 000 m		
ambient temperature			
 during operation 	-25 +60 °C		
during storage	-55 +80 °C		
relative humidity minimum	10 %		
relative humidity at 55 °C according to IEC 60068-2-30 maximum	95 %		

Main circuit	
number of poles for main current circuit	3
number of NO contacts for main contacts	3
operating voltage	
 at AC-3 rated value maximum 	690 V
 at AC-3e rated value maximum 	690 V
operational current	
 at AC-1 at 400 V at ambient temperature 40 °C rated value 	70 A
● at AC-1	
 — up to 690 V at ambient temperature 40 °C rated value 	70 A
— up to 690 V at ambient temperature 60 °C rated value	60 A
• at AC-3	
— at 400 V rated value	51 A
— at 500 V rated value	51 A
— at 690 V rated value	24 A
• at AC-3e	
— at 400 V rated value	51 A
— at 500 V rated value	51 A
— at 690 V rated value	24 A
 at AC-4 at 400 V rated value 	41 A
 at AC-5a up to 690 V rated value 	61.6 A
• at AC-5b up to 400 V rated value	41.5 A
● at AC-6a	
— up to 230 V for current peak value n=20 rated value	43.2 A
 up to 400 V for current peak value n=20 rated value 	43.2 A
 — up to 500 V for current peak value n=20 rated value 	43.2 A
 — up to 690 V for current peak value n=20 rated value 	24 A
 at AC-6a up to 230 V for current peak value n=30 rated value 	28.8 A
 — up to 400 V for current peak value n=30 rated value 	28.8 A
 — up to 500 V for current peak value n=30 rated value 	28.8 A
— up to 690 V for current peak value n=30 rated value	24 A
minimum cross-section in main circuit at maximum AC-1 rated value operational current for approx. 200000 operating	25 mm ²
cycles at AC-4	
 at 400 V rated value 	24 A
• at 690 V rated value	20 A
operational current	
• at 1 current path at DC-1	
— at 24 V rated value	55 A
— at 110 V rated value	4.5 A
— at 220 V rated value	1A
— at 440 V rated value	0.4 A
— at 600 V rated value	0.25 A
 with 2 current paths in series at DC-1 	
— at 24 V rated value	55 A
— at 110 V rated value	45 A
— at 220 V rated value	5 A
— at 440 V rated value	1A
— at 600 V rated value	0.8 A
	0.07
 with 3 current paths in series at DC-1 	

— at 24 V rated value	55 A
— at 110 V rated value	55 A
— at 220 V rated value	45 A
— at 440 V rated value	2.9 A
— at 600 V rated value	1.4 A
 at 1 current path at DC-3 at DC-5 	
— at 24 V rated value	35 A
— at 110 V rated value	2.5 A
— at 220 V rated value	1 A
— at 440 V rated value	0.1 A
— at 600 V rated value	0.06 A
 with 2 current paths in series at DC-3 at DC-5 	
— at 24 V rated value	55 A
— at 110 V rated value	25 A
— at 220 V rated value	5 A
— at 440 V rated value	0.27 A
— at 600 V rated value	0.16 A
• with 3 current paths in series at DC-3 at DC-5	0.1074
- at 24 V rated value	55 A
— at 24 v rated value — at 110 V rated value	55 A
- at 220 V rated value	25 A
- at 440 V rated value	0.6 A
— at 600 V rated value	0.35 A
operating power	
• at AC-2 at 400 V rated value	22 kW
• at AC-3	
— at 230 V rated value	15 kW
— at 400 V rated value	22 kW
— at 500 V rated value	30 kW
— at 690 V rated value	22 kW
• at AC-3e	
— at 400 V rated value	22 kW
— at 500 V rated value	30 kW
— at 690 V rated value	22 kW
operating power for approx. 200000 operating cycles	
at 400 V rated value	12.6 kW
at 690 V rated value	18.2 kW
operating apparent power at AC-6a	
• up to 230 V for current peak value n=20 rated value	17.2 kVA
• up to 400 V for current peak value n=20 rated value	29.9 kVA
• up to 500 V for current peak value n=20 rated value	37.4 kVA
up to 690 V for current peak value n=20 rated value	28.6 kVA
operating apparent power at AC-6a	
• up to 230 V for current peak value n=30 rated value	11.4 kVA
 up to 400 V for current peak value n=30 rated value 	19.9 kVA
 up to 500 V for current peak value n=30 rated value 	24.9 kVA
up to 690 V for current peak value n=30 rated value	28.6 kVA
short-time withstand current in cold operating state up to 40 °C	
 limited to 1 s switching at zero current maximum 	937 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 5 s switching at zero current maximum 	697 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 10 s switching at zero current maximum 	468 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 30 s switching at zero current maximum 	282 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 60 s switching at zero current maximum 	229 A; Use minimum cross-section acc. to AC-1 rated value
no-load switching frequency	
• at AC	5 000 1/h
operating frequency	
• at AC-1 maximum	1 000 1/h
• at AC-2 maximum	600 1/h
• at AC-3 maximum	800 1/h

a at AC 30 maximum	800 1/b
• at AC-3e maximum	800 1/h
• at AC-4 maximum	250 1/h
Control circuit/ Control	
type of voltage of the control supply voltage	AC
control supply voltage at AC	
• at 50 Hz rated value	110 V
operating range factor control supply voltage rated	
value of magnet coil at AC	
• at 50 Hz	0.8 1.1
apparent pick-up power of magnet coil at AC	400.1/4
• at 50 Hz	190 VA
inductive power factor with closing power of the coil	0.70
• at 50 Hz	0.72
apparent holding power of magnet coil at AC	16 VA
• at 50 Hz	10 VA
inductive power factor with the holding power of the coil	
• at 50 Hz	0.37
closing delay	
• at AC	10 80 ms
opening delay	
• at AC	10 18 ms
arcing time	10 20 ms
control version of the switch operating mechanism	Standard A1 - A2
Auxiliary circuit	
number of NC contacts for auxiliary contacts	1
instantaneous contact	
number of NO contacts for auxiliary contacts	1
instantaneous contact	
operational current at AC-12 maximum	10 A
operational current at AC-15	
 at 230 V rated value 	10 A
 at 400 V rated value 	3 A
 at 500 V rated value 	2 A
• at 690 V rated value	1 A
operational current at DC-12	
 at 24 V rated value 	10 A
 at 48 V rated value 	6 A
 at 60 V rated value 	6 A
 at 110 V rated value 	3 A
• at 125 V rated value	2 A
• at 220 V rated value	1 A
• at 600 V rated value	0.15 A
operational current at DC-13	
• at 24 V rated value	10 A
• at 48 V rated value	2 A
• at 60 V rated value	2 A
• at 110 V rated value	1 A
• at 125 V rated value	0.9 A
• at 220 V rated value	0.3 A
• at 600 V rated value	0.1 A
contact reliability of auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)
UL/CSA ratings	
full-load current (FLA) for 3-phase AC motor	
• at 480 V rated value	52 A
• at 600 V rated value	52 A
yielded mechanical performance [hp]	
 for single-phase AC motor 	
— at 110/120 V rated value	3 hp
— at 230 V rated value	10 hp
 for 3-phase AC motor 	

	15 hr		
— at 200/208 V rated value	15 hp		
- at 220/230 V rated value	15 hp		
- at 460/480 V rated value	40 hp		
— at 575/600 V rated value	50 hp		
contact rating of auxiliary contacts according to UL	A600 / P600		
Short-circuit protection			
design of the fuse link			
for short-circuit protection of the main circuit			
 — with type of coordination 1 required 	gG: 160 A (690 V, 100 kA), aM: 80 A (690 V, 100 kA), BS88: 125 A (415 V, 80 kA)		
— with type of assignment 2 required	gG: 80A (690V,100kA), aM: 50A (690V,100kA), BS88: 63A (415V,80kA)		
 for short-circuit protection of the auxiliary switch 	gG: 10 A (500 V, 1 kA)		
required	90. 1077 (000 V, 1107)		
Installation/ mounting/ dimensions			
mounting position	+/-180° rotation possible on vertical mounting surface; can be tilted		
	forward and backward by +/- 22.5° on vertical mounting surface		
fastening method	screw and snap-on mounting onto 35 mm standard mounting rail according to DIN EN 60715		
side-by-side mounting	Yes		
height	114 mm		
width	55 mm		
depth	130 mm		
required spacing			
• with side-by-side mounting			
— forwards	10 mm		
— upwards	10 mm		
— downwards	10 mm		
— at the side	0 mm		
for grounded parts			
— forwards	10 mm		
— upwards	10 mm		
— at the side	6 mm		
— downwards	10 mm		
for live parts			
— forwards	10 mm		
— upwards	10 mm		
— downwards	10 mm		
— at the side	6 mm		
Connections/ Terminals			
type of electrical connection			
for main current circuit	screw-type terminals		
for auxiliary and control circuit	screw-type terminals		
at contactor for auxiliary contacts	Screw-type terminals		
of magnet coil type of connectable conductor cross-sections	Screw-type terminals		
for main contacts			
solid or stranded	2x (1 35 mm²), 1x (1 50 mm²)		
 — finely stranded with core end processing 	2x (1 35 mm²), 1x (1 35 mm²)		
at AWG cables for main contacts	2x (18 2), 1x (18 1)		
connectable conductor cross-section for main			
contacts			
 finely stranded with core end processing 	1 35 mm²		
connectable conductor cross-section for auxiliary contacts			
 solid or stranded 	0.5 2.5 mm ²		
 finely stranded with core end processing 	0.5 2.5 mm ²		
type of connectable conductor cross-sections			
 for auxiliary contacts 			
— solid or stranded	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)		
 — finely stranded with core end processing 	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)		
 at AWG cables for auxiliary contacts 	2x (20 16), 2x (18 14)		

section • for auxiliary contacts • for auxiliary contacts • for auxiliary contacts • for auxiliary contacts • contact according to EC 609471 • positive driven operation according to EC 60947 • on the dremand rate according to SN 31920 • with high demand rate according to EC 60947- • with exportants • with high demand rate according to EC 60947- • with exportants • with high demand rate according to EC 60947- • with exportants • with high demand rate according to EC 60947- • with exportants • with exportants		ded connectable cond	uctor cross				
• for auxiliary contacts 2014 Statery rotated data Product function • mirror contact according to IEC 60847-4.1 Yes • B10 value with high demand rate according to SN 31820 1 000 000 proportion of dangerous failures 40 % • with how demand rate according to SN 31820 1 000 000 proportion of dangerous failures 40 % • with how demand rate according to SN 31820 73 % failure rate [FIT] with low demand rate according to SN 31820 20 y incertain failures 40 % • with how demand rate according to SN 31820 20 y incertain failures 20 y incertain failures </th <th></th> <th></th> <th></th> <th></th> <th></th> <th></th>							
Safety related data product function mirror contrate according to IEC 60947-41 positively driven operation according to SN 31920 No B10 value with high demand rate according to SN 31920 with high demand rate according to IEC 80629 witability for use safely-related switching OFF Yes 20 y Confirmation WE General Product Approvals General Product Approvals EXC Functional Safety/Safety of Machinery Machine / Shipping warine / Shipping </th <th colspan="3"></th> <th colspan="3"></th>							
product function • mirror contact according to EC 60947-41 Yes • positively driven operation according to EC 60947- 5-1 1000 000 proportion of dangerous failures 40 %. • with high demand rate according to SN 31920 40 %. • with high demand rate according to SN 31920 73 %. failure rate [F1] with low demand rate according to SN 31920 73 %. 102 state with high demand rate according to SN 31920 73 %. failure rate [F1] with low demand rate according to EC 60529 20 y protection class IP on the front according to IEC 60529 IP20 for use • safely-related switching OFF Yes centratice/sports/site Confirmation KC Effic Centratice/sports/site Confirmation KC Effic Centratice/sports/site Confirmation KC Effic Effic Safety/Safety of Machinery Declaration of Conformity Test Centificates files/feel/site Safety/Safety of Machinery Special Test Centific Special Test Centific site Safety/Safety of Machinery Special Test Centific Special Test Centific Special Test Centific Sec Safety/Safety of Mach	-						
• mirror contact according to IEC 60947-4.1 No • positively driven operation according to SN 31920 1000 000 Proportion of dangrouss failures 000 000 • with high demand rate according to SN 31920 1000 000 • with high demand rate according to SN 31920 100 000 • with high demand rate according to SN 31920 40 % • with high demand rate according to SN 31920 73 % failure rate [FI] with we demand rate according to SN 31920 73 % failure rate [FI] with we demand rate according to SN 31920 73 % failure rate [FI] with we demand rate according to IEC 60529 100 FIT stately related switching OFF Yes Confirmation Yes Confirmation Eff. Stately/Safety of Machinery Declaration of Conformity Test Certificates Stately/Safety of Machinery Martine / Shipping Type Examination Certificates State Safety/Safety of Machinery Declaration of Conformity Test Certificates State Safety/Safety of Machinery Declaration of Conformity Test Certificates State Safety/Safety of Machinery Declaration of Conformity Test Certificates Safety/Safety of Machinery Safety/Safety of Safety of Machinery Safety/Safety				_		_	
• positively driven operation according to EIC 60947- 5-1 No B10 value with high demand rate according to SN 31920 1 000 000 proportion of dangerous failures 40 % • with high demand rate according to SN 31920 73 % failure rate [F17] with low demand rate according to SN 31920 73 % failure rate [F17] with low demand rate according to SN 31920 20 y protection class IP on the front according to IEC IP20 costa 0 on the front according to IEC IP20 costa 0 on the front according to IEC IP20 costa 0 on the front according to IEC IP20 costa 0 on the front according to IEC IP20 costa 0 on the front according to IEC 60529 Ingersate, for vertical contact from the front suitability for use • safety-related switching OFF Yes confirmation Confirmation Confirmation cccc Confirmation Confirmation ccc Safety/Safety of Accord Declaration of Conformity Test Certificates safety/Safety of Safety Safety/Safety of Accord Safety/Safety of Accord Special Test Certificates safety Safety <	•	ecording to IEC 60947.	.1_1	Vec			
B10 value with high demand rate according to SN 31920 1 000 000 proportion of dangerous failures 40 % • with high demand rate according to SN 31920 40 % • with high demand rate according to SN 31920 73 % failure rate [FIT] with low demand rate according to SN 31920 73 % failure rate [FIT] with low demand rate according to SN 31920 20 y protection class IP on the front according to IEC IP20 for the protection on the front according to IEC IP20 stately for use • safety-related switching OFF Yes Confirmation Yes Confirmation Confirmation KC ENC Functional Safety/Safety of Confirmation Declaration of Conformity Test Certificates Safety/Safety of Safety Declaration of Conformity Test Certificates Marine / Shipping Image: Safety Special Test Certificates Marine / Shipping other Railway Dangerous Good Marine / Shipping Confirmation Vibration and Shock Tangerous Good Image: Safety	 positively driver 	-					
proportion of dangerous failures 40 % • with how demand rate according to SN 31920 40 % • with high demand rate according to SN 31920 73 % failure rate [FIT] with low demand rate according to SN 31920 100 FIT 31920 71 Yalue for proof test interval or service life according to SN 31920 20 y It's value for proof test interval or service life according to IEC 60529 100 FIT suitability for use estely-related switching OFF Yes Confirmation Yes KC Efficient Confirmation Exc. Confirmation KC Efficient EMC Punctional Stately/Safety of Machinery Declaration of Conformity Test Certificates Stately/Safety of Machinery Declaration of Conformity Test Certificates Special Test Certific ates Martine / Shipping Image: Safety/Safety of Machinery Declaration of Conformity Type Test Certific ates Special Test Certific ate Martine / Shipping Type Examination Efficient Special Test Certific ate Special Test Certific at				4 000 000			
• with low demand rate according to SN 31920 40 % • with high demand rate according to SN 31920 73 % faluer rate [TT] with low demand rate according to SN 100 FIT 51930 100 FIT T1 value for proof test interval or service life according to IEC 20 y protection class IP on the front according to IEC 60529 inger-safe, for vertical contact from the front suitability for use • ves • safety-related switching OFF Yes Confirmation Ves Confirmation Confirmation • ves Ves Confirmation Ves Confirmation Ves Confirmation Ves Confirmation Ves Confirmation Ves Confirmation Ves Ves Ves Ves Ves Confirmation Ves Ves Ves <th></th> <th></th> <th>0 SN 31920</th> <th colspan="4">1 000 000</th>			0 SN 31920	1 000 000			
• with high demand rate according to SN 31920 73 % failure rate [FT] with low demand rate according to SN 100 FT 31920 20 y EC 61503 20 y Protection class IP on the front according to IEC 60529 inger-safe, for vertical contact from the front scoording to IEC 60529 suitability for use yes • safe/y-related switching OFF Yes Central Product Approvals Confirmation General Product Approval EMC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates Safety/Safety of Machinery Declaration of Conformity Type Test Certificates Martine / Shipping Iver Examination Certificate Special Test Certific ates Martine / Shipping Other EMC Special Test Certific ates Martine / Shipping Other Railway Dangerous Good Martine / Shipping Other Railway Dangerous Good Wartine / Shipping Confirmation Vibration and Shock Transport Information			21020	40.9/			
failure rate [FIT] with low demand rate according to SN 31920 100 FIT 11 value for proof test interval or service life according to IEC 61508 20 y protection class IP on the front according to IEC 6529 IP20 sitability for use • safety-related switching OFF Yes Confirmation EMC Functional Safety/Safety of Machinery Confirmation EMC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates ates/Test Report Sign Upper Examination Certificate Type Test Certific ate Special Test Certific ate Marine / Shipping Upper Examination Certificate Type Test Certific ate Special Test Certific ate Marine / Shipping Other Railway Dangerous Good Warine / Shipping Confirmation Vibration and Shock Transport Informa- bon		-					
IEC 61508 Image: same intervention of the front according to IEC 60529 Inger-safe, for vertical contact from the front suitability for use • safety-related switching OFF Yes Centrificates/ approvals Yes Centrificates/ approvals Confirmation Image: safety of the front according to IEC 60529 Image: safety-related switching OFF Yes Yes Centrificates/ approvals Confirmation Image: safety of the front	failure rate [FIT] with						
increase in the front according to IEC 60529 Ves Certificates approvals Continuation Confirmation of Conformity Examination Certificate Certificate Impreval Marine / Shipping Other Reliway Superior Confirmation Superior Confirmation Superior Confirmation Superior Confirmation Superior Confirmation Superior Co		t interval or service life	according to	20 y			
suitability for use • safety-related switching OFF Yes Centificates/ approvals General Product Approval Confirmation <		on the front according	to IEC	IP20			
Yes Certificates/ approvals Centificates/ approvals Centeral Product Approval Confirmation Confirmation KC Efficient EMC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates Special Test Certific ates/Test Certif	touch protection on	the front according to	IEC 60529	finger-safe, for vertica	al contact from the front		
Certificates/approval General Product Approval Confirmation EV KC Efficience EMC Functional Satety/Safety of Machinery Declaration of Conformity Test Certificates EMC Functional Satety/Safety of Machinery Declaration of Conformity Test Certificates EMC Functional Satety/Safety of Machinery Declaration of Conformity Test Certificates EMC Functional Satety/Safety of Machinery Declaration of Conformity Test Certificates EMC Functional Satety/Safety of Machinery Declaration of Conformity Test Certificates EMC Functional Satety/Safety of Machinery Declaration of Conformity Test Certificates EMC Izype Examination Certificate Efficience Special Test Certificates Marine / Shipping Izype Examination Certificate Izype Test Certificates Efficience EMS Efficience Efficience Izype Test Certificates Special Test Certificates Marine / Shipping other Railway Dangerous Good Efficience EMS Confirmation Vibration and Shock Transport Information Information	-						
General Product Approval General Product Approval Confirmation ENC KC ENC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates EMC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates Image: Certificate Image: Certificate Image: Certificate Image: Certificate Image: Certificate Marine / Shipping Image: Certificate Image: Certificate Image: Certificate Image: Certificate Image: Certificate Marine / Shipping Image: Certificate Image: Certificate Image: Certificate Image: Certificate Image: Certificate Image: Certificate Image:	-	-		Yes			
Image: Section of Confirmation Image: Section of Confirmation Image: Section of Confirmation Image: Section of Confirmation EMC Functional Safety/Safety of Machinery Declaration of Conformity Test Certificates Image: Section of Confirmation Certificate Type Examination Certificate Type Test Certificates Special Test Certificate Image: Section of Confirmation Certificate Type Examination Certificate Image: Section of Confirmation Certificate Image: Section of Certificat	Certificates/ approval	S					
Image: Section of Conformation of Conformity Test Certificates EMC Functional Stately/Safety of Machinery Declaration of Conformity Test Certificates Image: Section of Conformity Type Examination Certificate Type Test Certificate Special Test Certificate Image: Section of Conformity Image: Section of Certificate Image: Section of Certificate Special Test Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Special Test Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate Image: Section of Certificate	General Product Ap	proval					
EMC Safety/Safety of Machinery Declaration of Conformity Test Certificates Image: Second Certificate Type Test Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Special Test Certificate Image: Second Certificate Image: Second Certificate Image: Second Certificate Image: Second Certificate Image: Second Certificate Image: Second Certificate Image: Second Certificate	CSA	ccc		UL			
CertificateCertificateates/Test ReportateMarine / ShippingImage: Single	EMC	Safety/Safety of	Declaration of	of Conformity	Test Certificates		
Image: Note of the sector o	RCM					<u>Special Test Certific-</u> <u>ate</u>	
Marine / Shipping other Railway Dangerous Good Image: Shipping in the state of the state o	Marine / Shipping						
Confirmation Confirmation Vibration and Shock Transport Informa- tion	ABS	BUREAU VERITAS		Lloyd's Register urs	PRS	RINA	
Confirmation Confirmation Vibration and Shock Transport Informa- tion	Marine / Shipping	other		Railway	Dangerous Good		
			Confirmatio		Shock Transport Informa-		

Further information

Information- and Downloadcenter (Catalogs, Brochures,...) https://www.siemens.com/ic10 Industry Mall (Online ordering system) https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RT2036-1AF00 Cax online generator http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RT2036-1AF00 Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3RT2036-1AF00 Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RT2036-1AF00&lang=en Characteristic: Tripping characteristics, I²t, Let-through current https://support.industry.siemens.com/cs/ww/en/ps/3RT2036-1AF00/char Further characteristics (e.g. electrical endurance, switching frequency) http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RT2036-1AF00&objecttype=14&gridview=view1

last modified:

2/15/2022 🖸